



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/School/SZ/2024/975

Dated: 04/10/2024

FIRE SAFETY CERTIFICATE

Certified that the **Green Valley Public School** located at **Hari Nagar, Jaitpur Road, Badarpur, New Delhi-44**, comprised of comprised of Two blocks A Block - Ground floor only & B Block - Ground + 01 upper floor, was granted Fire Safety Certificate by this department vide letter no. F.6/DFS/MS/School/2021/SZ/931 dated 12.11.2021. The school building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 01.10.2024 in the presence of Mr. Nitin Chopra (Vice Principal) and found that school building is now comprised of Two blocks **A Block - Ground + 01 upper floor (1st floor vacant) & B Block - Ground + 02 upper floors** and found that the building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises/building is fit for occupancy of Group B **"Educational Building" (School)** with effect from 04/10/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on 04/10/2024 at New Delhi by

(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Green Valley Public School located at Hari Nagar, Jaitpur Road, Badarpur, New Delhi-44.
3. The Executive Engineer (Bldg.), Municipal Corporation of Delhi, Jal Vihar, Lajpat Nagar, New Delhi-24.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc may be got verified from the authorities concerned.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner / occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub Rule (1) of Rule 37] along with a copy of this certificate, six months prior to its expiry.